

# Holyrood School

## Ventilation information

Mechanical ventilation systems are combined with stand-alone air filtration units in all instructional spaces, so all ASHRAE (American Society of Heating, Refrigerating and Air-Conditioning Engineers) guidelines are being met or exceeded, including air changes per hour.

Some mechanical systems in our Division schools are not able to have a MERV 13 filter installed. For these schools, the highest possible filter that meets the system requirements has been installed.

| Ventilation system measures                                 |                                     |
|---|-------------------------------------|
| Runs for two hours before and after regular operating times | <input checked="" type="checkbox"/> |
| Maximum fresh air intake                                    | <input checked="" type="checkbox"/> |

| Filtration measures   |                                     |
|---|-------------------------------------|
| MERV 13 filter (or highest possible filter option) installed  | <input checked="" type="checkbox"/> |
| Filters changed at least every three months                   | <input checked="" type="checkbox"/> |
| Number of stand-alone HEPA air filtration units in the school | <b>24</b>                           |